

IMPORTANT

Lagernummer: 57534 01/04 (BU)

OCC2 / OCD2 installation note

Please read before starting to install the thermostat

The OCC2/OCD2 thermostat is designed to be mounted in a metal wall conduit box (35mm deep) or a standard surface mount patress available from electrical stores, via the screws supplied through the two fixing holes on the sides of the thermostats and into the wall boxes.

TO REMOVE THE FRONT COVER , release the **TWO** fixing clips that are located inside the bottom of the air grills on each side of the cover. By inserting a small screwdriver and pressing against the clip, the cover is released and can be removed along with the outer frame and the back mounting plate.

DO NOT release the four fixing points that can be seen on each corner at the back of the thermostat.

OJ Electronics A/S

Stenager 13B · DK-6400 Sønderborg
Tel +45 73 12 13 14 · Fax +45 73 12 13 13
www.oj.dk

